



Product Service

# Attestation of Conformity

No. N8A 108181 0004 Rev. 03

**Holder of Certificate:** **ET SOLAR POWER HONGKONG LIMITED**  
Room 01,21/F, XINGFA Commercial Building  
9th Tobacco Factory Street  
Mong Kok  
HONG KONG

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061917001-04

**Date,** 2021-04-23

( Zhulin Zhang )

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



# Attestation of Conformity

No. N8A 108181 0004 Rev. 03

## Model(s):

156.75 cell modules

ET-M672xxxWW, ET-M672xxxWB (xxx=370 to 390 in step of 5)

ET-M660xxxWW, ET-M660xxxWB (xxx=310 to 325 in step of 5)

158.75 cell modules

ET-M672BHxxxWW, ET-M672BHxxxWB (xxx=385 to 420 in step of 5)

ET-M660BHxxxWW, ET-M660BHxxxWB (xxx=320 to 350 in step of 5)

ET-M672BHxxxBB (xxx=385 to 410 in step of 5)

ET-M660BHxxxBB (xxx=320 to 340 in step of 5)

ET-M672BHxxxTW, ET-M672BHxxxTB (xxx=385 to 420 in step of 5)

ET-M660BHxxxTW, ET-M660BHxxxTB (xxx=325 to 350 in step of 5)

166 cell modules

ET-M672BHxxxWW, ET-M672BHxxxWB (xxx=425 to 455 in step of 5)

ET-M660BHxxxWW, ET-M660BHxxxWB (xxx=355 to 375 in step of 5)

ET-M672BHxxxBB (xxx=415 to 445 in step of 5)

ET-M660BHxxxBB (xxx=345 to 370 in step of 5)

ET-M672BHxxxTW, ET-M672BHxxxTB (xxx=435 to 455 in step of 5)

ET-M660BHxxxTW, ET-M660BHxxxTB (xxx=360 to 375 in step of 5)

182 cell modules

ET-M772BHxxxWW, ET-M772BHxxxWB (xxx=520 to 555 in step of 5)

ET-M766BHxxxWW, ET-M766BHxxxWB (xxx=475 to 505 in step of 5)

ET-M754BHxxxWW, ET-M754BHxxxWB (xxx=390 to 415 in step of 5)

ET-M772BHxxxTW, ET-M772BHxxxTB (xxx=520 to 555 in step of 5)

ET-M766BHxxxTW, ET-M766BHxxxTB (xxx=475 to 505 in step of 5)

ET-M754BHxxxTW, ET-M754BHxxxTB (xxx=390 to 415 in step of 5)

The suffix WW stands for silvery frame and white backsheet

The suffix WB stands for black frame and white backsheet

The suffix BB stands for black frame and black backsheet

The suffix TW stands for silvery frame and transparent backsheet

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 108181 0004 Rev. 03

The suffix TB stands for black frame and transparent backsheet

xxx stands for rated output power at STC

## Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone Changzhou, Jiangsu, China.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06